

City of The Dalles Water Quality Lab  
Microbiology Report

PWS# 41  
 PWS Name: \_\_\_\_\_  
 City, County: Hood River / Hood River  
 Phone: 541-499-6127 Email: john.fid@hoodriverelectric.net  
 Return address for report:  
 Name: East Fork Irrigation District  
 Address: P.O. Box 162  
 City, State, Zip: Odell, Oregon 97031

ORELAP#: OR100002  
 Lab Name: City of The Dalles Water Quality Lab  
 Address: 6780 Reservoir Road The Dalles  
 Phone/Fax: 541-298-2248 x5009/541-298-2129  
 Bottle#: E12 Report to DHS? YES  NO  
 Lab Sample ID# 207330

Sample Collected Date/Time: 04 / 27 / 2021 11:45  AM  PM  
 Chlorinated:  No  Yes  
 Collected By: John Buckley Free Chlorine: \_\_\_\_\_ mg/L

DISTRIBUTION Sample Type:  Routine  \*Repeat  Temporary Routine  Special  
 \*Date of Initial Positive: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ \*Original Positive ID#: \_\_\_\_\_  
 Address: \_\_\_\_\_ Sampled at (ex. "SINK"): \_\_\_\_\_

SOURCE Sample Type:  \*Triggered  \*Confirmation  Assessment  Special  
 \*Date of Initial Positive: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ \*Original Positive ID#: \_\_\_\_\_  
 Source ID: SRC- \_\_\_\_\_ Source name (ex. "WELL #1"): \_\_\_\_\_

Delivered By: John Buckley / Steve Pappas Date: 4-27-2021

**LAB USE ONLY**  
 Sample Received Date/Time: 4 / 27 / 21 3:22  AM  PM Initials: WA Temp: 21 °C  
 Evidence of cooling?  Yes  No

Analysis Start Date/Time: 4 / 28 / 2021 11:22  AM  PM Initials: DKR  
 ORELAP Method(s):  Colilert® SM Online Ed/SM 9223B  Quantity Tray 2K  Other: \_\_\_\_\_

- Sample Results do not meet NELAC Standards because (check all that apply):  
 Not received in lab-supplied bottle  
 Not incubated at proper temperature  
 Not received at proper temperature (below 10°C)  
 Other Reason: \_\_\_\_\_  
 Sample invalidation:  
 Over 30 hours  
 Heavy non-coliform growth  
 Leak

**Test Results:**  
 Total Coliforms:  Present  Absent  
 E. Coli:  Present  Absent  
 Total Coliforms: NA MPN/100mls  
 E. Coli: 1.0 MPN/100mls  
 Analysis Complete Date/Time: 4 / 29 / 2021 11:36 AM  
 Analyst: Ramos  
 Review by: JMM 4 / 29 / 21

Reported By: JMM Report Date: 4 / 29 / 21

Tests results sent:  Email  Mail  Fax OHA  Fax  Call  
 Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAC unless otherwise noted. This report shall not be reproduced except in full, without written consent of this laboratory.  
 DHS USE ONLY